

## **Hospital Occupancies Owner / Occupant Inspection Information**

*The B.C. Fire Code requires building owners/occupants to comply with the requirements on this checklist.*

These requirements are in addition to those listed in the Fire Safety & You brochure.

### **Hospital Uses Include:**

- hospitals
- health care facilities
- residential care facilities

### **Checklist: Common Fire Service Requirements**

- **Address:** must be visible from road and lane, free from foliage, trees, etc. and in a contrasting colour.
- **Compressed gases:** must be held in a secure storage area (outside).
- **Emergency lighting:** may be provided by battery packs with remote and attached heads, or by emergency generators that will illuminate specified A/C fixtures or remote light heads. Must be operational, with no visible damage, with heads aimed in proper direction, and serviced and tagged annually by a certified technician.
- **Exit doors:** must not be locked or blocked from either the inside or outside. Must be unlocked from the inside when the building is occupied. Must have panic hardware that releases when a force of 20 pounds or less is applied.
- **Exit signs:** must be visible and remain illuminated at all times the building is occupied.
- **Fire alarm systems:** must have a working A/C power-on bulb and be in good working condition with no audible or visual damage. Must have a current service tag (within the last 12 months) and up-to-date logbook.
- **Fire doors:** must not be blocked or wedged open, including stairwell doors. Must have closures and no hold-open devices may be attached.
- **Fire hose cabinets:** there must be clear access to cabinets and the hose must be in good repair and complete with nozzles.
- **Fire hydrants:** must be accessible, free of damage and serviced within the specified date. Private hydrants require annual service, with records kept on site.

- **Fire lanes:** must have an adequate clear width of six unobstructed metres from building.
- **Fire Safety Plan:** must be reviewed and updated yearly.
- **No smoking' signs:** must be posted in hazardous areas.
- **Portable fire extinguishers:** must:
  - Be located adjacent to corridors or aisles that provide access to exits.
  - Be mounted in a visible location, accessible, and serviced and tagged at least once every 12 months by a certified technician.
  - Be full and functioning (no damage, corrosion, leaks, malfunctioning parts or clogged nozzles).
  - Have a minimum rating 2A-10BC.
- **Sprinkler and standpipe connections:** must be capped, free of debris and accessible.
- **Sprinkler valves:** must be in the open position, either locked and chained or sealed and monitored electronically. No storage is permitted within 18 inches of the bottom of sprinkler heads.